GENERAL NOTES:

1. DISCHARGE WATER PIPING TO BE SCH 40 A-106 SMLS. STL., WITH 3000# FORGED STL SOCKET WELD FITTINGS BORED FOR SCH 40 PIPE
2. ALL WELDING SHALL BE DONE IN ACCORDANCE WITH THE ANSI CODE FOR PETROLEUM PIPING SECTION B31-3 LATEST REVISION
3. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE SUBCONTRACT SPECIFICATIONS

PSF
CERTIFIED FOR CONSTRUCTION
DATE 4/19/73

REFERENCE DRAWINGS
EM-13165-AC & EM-13165-H

REVIEWED FOR CLASSIFICATION
Initials
6/24/99
Date
UNCLASSIFIED

			SCALE AS NOTED	DESIGN BY J DEJWC	1973
			TOLERANCES UNLESS OTHERWISE SPECIFIED X DIM. MAY VARY ± XX DIM. MAY VARY ± XXX DIM. MAY VARY ± X DIM. MAY VARY ± 1/8	DRAWN BY J. ELLIOTT	2-8
				CHECKED BY WJM	2-19
ELEC.	INST.	FIELD		APPROVAL DEPT	2-23
				OPER LAD	2/22
				DIV	3/8
			R.C.D. NO. 13165	S & P.P. RCB	2/21
CHECK			B.M. NO.	F.D. NJA	2/21

UNION CARBIDE CORPORATION
NUCLEAR DIVISION — PADUCAH PLANT

COMPR. SHOP MODIFICATION
WASTE WATER SYSTEM
PLAN & DETAILS

BLDG. NO. C-720
LOCATION COMPR. SHOP

EM-13165-ABREV. 1

GDP0482 ORF00006247